

Poy, Thomas

From: Deltoral, Miguel
Sent: Tuesday, August 16, 2016 1:57 PM
To: Poy, Thomas
Cc: Mary Hollingsworth; Hyde, Tinka; Bair, Rita; Shoven, Heather; Porter, Andrea; Spaulding, William
Subject: Re: Draft Talking Points - East Chicago

Mary - can you confirm what they are using for corrosion control? I hope that they are not using only polyphosphates as this is not corrosion control. Polyphosphates only sequester dissolved iron/manganese, they do not control lead release and in high amounts they can actually increase lead release. The ortho/poly terminology is always confused so I'm assuming and hoping it is actually orthophosphate or blended (ortho + poly) phosphates.

Miguel A. Del Toral
Regulations Manager, GWDWB
U.S. EPA Region 5 (WG-15J)
77 West Jackson Blvd
Chicago, IL 60604
W: (312) 886-5253

On Aug 16, 2016, at 1:37 PM, Poy, Thomas <poy.thomas@epa.gov> wrote:

Mary: I've drafted the attached talking points regarding East Chicago's drinking water and lead. Can you please take a look at it and let me know if you have any concerns. As I mentioned in the voicemail that I left for you, the talking points will be provided to our Superfund staff for a public meeting tonight.

Tom

Tom Poy
Chief, Ground Water and Drinking Water Branch
USEPA - Region 5
(312) 886-5991

<Talking Points for East Chicago Drinking Water.docx>

